

## FLOW RESTRICTORS (BALL VALVES)

Maryland Department of the Environment

- COMAR 26.10.03.03A.(2)

(a) Overfill prevention equipment shall:

(2)(b) Flow restrictors (ball floats) are no longer an option when overfill prevention is installed or replaced after the effective date.

Federal Regulations

40 CFR §280.20.C.3 Performance standards for new UST systems

(3) Flow restrictors used in vent lines may not be used to comply with paragraph (c)(1)(ii) of this section when overfill prevention is installed or replaced after October 13, 2015.