

## **SPILL BUCKET INSTALLATION**

### **TO DO LIST**

#### **SITE RESPONSIBILITY**



	After 24 hours, Remove cones from tank field. Set aside. If we left cones, we'll return to retrieve.
	After 24 hours, open Spill Bucket lid and remove shims (if applicable). <ul style="list-style-type: none"> <li>• Photos and video below for visually representation.</li> </ul>

#### **CONTACT**



	Please contact our office with any questions at 443-288-1860
--	--

#### **REPORTING**



	Check email from technicians close out and retain copy of Spill Bucket test. <ul style="list-style-type: none"> <li>• Maryland: testing required annually.</li> <li>• Virginia: testing required every 3 years.</li> <li>• DC: testing required every 3 years.</li> <li>• Pennsylvania: testing required every 3 years.</li> <li>• Delaware: testing required annually.</li> <li>• West Virginia: testing required every 3 years.</li> </ul>
--	--